


This document, together with the concepts and designs presented herein, is intended only for the specific purpose and client for which it was prepared. Reuse of and improper reliance on this document without written authorization and adaptation by Kinney-Horn and Associates, Inc. shall be without liability to Kinney-Horn and Associates, Inc.



LEGEND

BRANCH IDENTIFIER	
RW01:10	SECTION IDENTIFIER
—	SECTION BOUNDARY
	PCI 86-100 GOOD
	PCI 71-85 SATISFACTORY
	PCI 56-70 FAIR
	PCI 41-55 POOR
	PCI 26-40 VERY POOR
	PCI 11-25 SERIOUS
	PCI 0-10 FAILED

CURRENT 2024 PAVEMENT CONDITION INDEX


Branch ID	Section ID	Branch Name	Surface Type	Section Area (SF)	Approx. Age at Inspection	Last Major Work Date	Last Inspection Date	Pavement Condition Index	PCI Category
RW12	11	Runway 12-30	AC	228,000	7	11/1/2017	10/5/2024	85	Satisfactory
TW	01	Taxiway	AC	7,709	3.9	1/1/2021	10/5/2024	94	Good
TW	02	Taxiway	AC	5,746	7	11/11/2017	10/5/2024	89	Good
TW	03	Taxiway	AC	161,448	30.5	6/1/1994	10/5/2024	51	Poor
TW	04	Taxiway	AC	12,600	21.3	8/1/2003	10/5/2024	76	Satisfactory
TW	05	Taxiway	AC	71,505	11.2	9/1/2013	10/5/2024	78	Satisfactory
TW	06	Taxiway	AC	50,188	7	11/1/2017	10/5/2024	89	Good
TW	12	Taxiway	AC	20,783	3.9	1/1/2021	10/5/2024	92	Good
TW	13	Taxiway	AC	68,777	3.9	1/1/2021	10/5/2024	92	Good
AP	01	Apron	AC	70,000	3.9	1/1/2021	10/5/2024	94	Good
AP	02	Apron	AC	90,425	3.9	1/1/2021	10/5/2024	94	Good

AIRFIELD PAVEMENT WORK HISTORY

- ADAP-03, 1981, ORIGINAL CONSTRUCTION
SUBGRADE IS CEMENTED SILTY GRAVEL AND HARD PAN.
- AIP-001, OVERLAY RUNWAY, APRON, AND TAXIWAY.
- AIP-002-1994, CONSTRUCT PARTIAL PARALLEL TAXIWAY (TW:03); CONSTRUCT ACCESS TAXIWAY (TW:03); EXPAND APRON (AP:02).
- AIP-004-2003, CONSTRUCT TAXIWAY (TW:04); CRACK SEAL, FOG SEAL, AND REMARK REMAINING PAVEMENTS.
- AIP-009-2011, CRACK SEAL, FOG SEAL, AND REMARK ALL PAVEMENTS.
- AIP-010-2013, CONSTRUCT TAXIWAYS (TW:05).
- AIP-012-2015, RECONSTRUCT AND WIDEN RUNWAY 12-30 (RW12:11); CONSTRUCT PARALLEL TAXIWAY (TW:06).
- AIP-015-2019, RECONSTRUCT TAXIWAYS (TW:01, TW:13) AND APRONS (AP:01, AP:02); CONSTRUCT MIDFIELD TAXIWAY (TW:12)



This document, together with the concepts and designs presented herein, is intended only for the specific purpose and client for which it was prepared. Reuse of and improper reliance on this document without written authorization and adaptation by Kimley-Horn and Associates, Inc. shall be without liability to Kimley-Horn and Associates, Inc.



LEGEND


- BRANCH IDENTIFIER
- RW01:10** — SECTION IDENTIFIER
- SECTION BOUNDARY
- PCI 86-100 GOOD
- PCI 71-85 SATISFACTORY
- PCI 56-70 FAIR
- PCI 41-55 POOR
- PCI 26-40 VERY POOR
- PCI 11-25 SERIOUS
- PCI 0-10 FAILED

FORECASTED PAVEMENT CONDITION INDEX

Branch ID	Section ID	Surface Type	Current PCI (2024)	2025	2026	2027	2028	2029
RW12	11	AC	85	85	83	81	80	79
TW	01	AC	94	93	91	88	86	84
TW	02	AC	89	88	86	84	83	81
TW	03	AC	51	50	48	45	41	38
TW	04	AC	76	76	75	74	73	73
TW	05	AC	78	78	77	76	75	74
TW	06	AC	89	88	86	84	83	81
TW	12	AC	92	91	89	87	85	83
TW	13	AC	92	91	89	87	85	83
AP	01	AC	94	93	91	88	86	84
AP	02	AC	94	93	91	88	86	84



This document, together with the concepts and designs presented herein, is intended only for the specific purpose and client for which it was prepared. Reuse of and improper reliance on this document without written authorization and adaptation by Kimley-Horn and Associates, Inc. shall be without liability to Kimley-Horn and Associates, Inc.



LEGEND

— BRANCH IDENTIFIER	
— SECTION IDENTIFIER	
— SECTION BOUNDARY	
MAJOR REHABILITATION	GLOBAL TREATMENT
2025	2025
2026	2026
2027	2027
2028	2028
2029	2029

5-YEAR PAVEMENT NEEDS BY SECTION

Year	Branch ID	Section ID	Surface Type	Section Area (SF)	PCI at Treatment	Recommended Treatment	Treatment Category
2025	RW12	11	AC	228,000	85	Crack Seal and Seal Coat	Global Treatment
2025	TW	02	AC	5,746	88	Crack Seal and Seal Coat	Global Treatment
2025	TW	03	AC	161,448	50	Full-Depth Reconstruction	Major Rehabilitation
2025	TW	04	AC	12,600	76	Crack Seal and Seal Coat	Global Treatment
2025	TW	05	AC	71,505	78	Crack Seal and Seal Coat	Global Treatment
2025	TW	06	AC	50,188	88	Crack Seal and Seal Coat	Global Treatment
2026	TW	01	AC	7,709	91	Crack Seal and Seal Coat	Global Treatment
2026	TW	12	AC	20,783	89	Crack Seal and Seal Coat	Global Treatment
2026	TW	13	AC	68,777	89	Crack Seal and Seal Coat	Global Treatment
2026	AP	01	AC	70,000	91	Crack Seal and Seal Coat	Global Treatment
2026	AP	02	AC	90,425	91	Crack Seal and Seal Coat	Global Treatment



Runway



RW12-11-17: L&T Cracking



RW12-11-35: Weathering

Taxiway



TW-03-20: Alligator Cracking




TW-04-02: L&T Cracking

Apron



AP-01-10: Weathering



AP-02-08: Weathering

Re-Inspection Report

MDT SASP 2024

Generated Date

1/7/2025

Page 1 of 11

Network: 32S **Name:** Stevensville Airport

Branch: AP **Name:** Apron **Use:** APRON **Area:** 160,425 SqFt

Section: 01 of 2 **From:** ENTIRE APRON **To:** **Last Const.:** 1/1/2021

Surface: AC **Family:** _MDT2024 - AP AC **Zone:** STEV **Category:** D **Rank:** P

Area: 70,000 SqFt **Length:** 1,400 Ft **Width:** 50 Ft

Slabs: **Slab Length:** Ft **Slab Width:** Ft **Joint Length:** Ft

Shoulder: **Street Type:** STA **Grade:** 0 **Lanes:** 0

Section Comments:

Work Date: 9/30/1991 **Work Type:** New Construction - Initial **Code:** NU-IN **Is Major M&R:** True

Work Date: 1/1/2021 **Work Type:** Complete Reconstruction - AC **Code:** CR-AC **Is Major M&R:** True

Last Insp. Date: 10/5/2024 **TotalSamples:** 13 **Surveyed:** 5

Conditions: PCI: 94

Inspection Comments:

Sample Number: 03 **Type:** R **Area:** 4800.00 SqFt **PCI:** 94

Sample Comments:

57 WEATHERING L 4800.00 SqFt

Sample Number: 06 **Type:** R **Area:** 4800.00 SqFt **PCI:** 94

Sample Comments:

57 WEATHERING L 4800.00 SqFt

Sample Number: 07 **Type:** R **Area:** 4800.00 SqFt **PCI:** 94

Sample Comments:

57 WEATHERING L 4800.00 SqFt

Sample Number: 10 **Type:** R **Area:** 4800.00 SqFt **PCI:** 94

Sample Comments:

57 WEATHERING L 4800.00 SqFt

Sample Number: 14 **Type:** R **Area:** 5740.00 SqFt **PCI:** 94

Sample Comments:

57 WEATHERING L 5740.00 SqFt

Network:	32S	Name:	Stevensville Airport				
Branch:	AP	Name:	Apron	Use:	APRON	Area:	160,425 SqFt
Section:	02	of 2	From:	NORTH APRON	To:		Last Const.: 1/1/2021
Surface:	AC	Family:	_MDT2024 - AP AC	Zone:	STEV	Category:	D
Area:	90,425 SqFt	Length:	360 Ft	Width:	240 Ft		
Slabs:		Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft
Shoulder:		Street Type:	ACN	Grade:	0	Lanes:	0
Section Comments:							
Work Date:	6/1/1994	Work Type:	New Construction - Initial		Code:	NU-IN	Is Major M&R: True
Work Date:	1/1/2021	Work Type:	Complete Reconstruction - AC		Code:	CR-AC	Is Major M&R: True
Last Insp. Date:	10/5/2024	Total Samples:	19	Surveyed:	5		
Conditions:	PCI: 94						
Inspection Comments:							
Sample Number:	04	Type:	R	Area:	4800.00 SqFt	PCI:	94
Sample Comments:							
57	WEATHERING		L	4800.00	SqFt		
Sample Number:	08	Type:	R	Area:	4800.00 SqFt	PCI:	94
Sample Comments:							
57	WEATHERING		L	4800.00	SqFt		
Sample Number:	12	Type:	R	Area:	4800.00 SqFt	PCI:	94
Sample Comments:							
57	WEATHERING		L	4800.00	SqFt		
Sample Number:	16	Type:	R	Area:	4800.00 SqFt	PCI:	94
Sample Comments:							
57	WEATHERING		L	4800.00	SqFt		
Sample Number:	19	Type:	R	Area:	4025.00 SqFt	PCI:	94
Sample Comments:							
57	WEATHERING		L	4025.00	SqFt		

Network:	32S	Name:	Stevensville Airport						
Branch:	RW12	Name:	Runway 12-30	Use:	RUNWAY	Area:	228,000 SqFt		
Section:	11	of	1	From:	T-1	To:	T-6	Last Const.:	11/1/2017
Surface:	AC	Family:	_MDT2024 - RW AC AAC		Zone:	Category:	Rank: P		
Area:	228,000 SqFt	Length:	3,800 Ft	Width:	60 Ft				
Slabs:	Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft			
Shoulder:	Street Type:	Grade:	0	Lanes:	0				
Section Comments:									
Work Date:	11/1/2017	Work Type:	New Construction - AC		Code:	NC-AC	Is Major M&R:	True	
Last Insp. Date:	10/5/2024	TotalSamples:	48		Surveyed:	7			
Conditions:	PCI: 85	Inspection Comments:							
Sample Number:	05	Type:	R	Area:	4800.00 SqFt	PCI:	77		
Sample Comments:									
48	L & T CR	L	206.00	Ft					
48	L & T CR	M	20.00	Ft					
57	WEATHERING	L	4800.00	SqFt					
Sample Number:	10	Type:	R	Area:	4800.00 SqFt	PCI:	88		
Sample Comments:									
48	L & T CR	L	95.00	Ft					
57	WEATHERING	L	4800.00	SqFt					
Sample Number:	17	Type:	R	Area:	4800.00 SqFt	PCI:	84		
Sample Comments:									
48	L & T CR	L	160.00	Ft					
57	WEATHERING	L	4800.00	SqFt					
Sample Number:	23	Type:	R	Area:	4800.00 SqFt	PCI:	91		
Sample Comments:									
48	L & T CR	L	7.00	Ft					
57	WEATHERING	L	4800.00	SqFt					
Sample Number:	29	Type:	R	Area:	4800.00 SqFt	PCI:	82		
Sample Comments:									
48	L & T CR	L	82.00	Ft					
48	L & T CR	M	25.00	Ft					
57	WEATHERING	L	4800.00	SqFt					
Sample Number:	35	Type:	R	Area:	4800.00 SqFt	PCI:	82		
Sample Comments:									
48	L & T CR	L	105.00	Ft					
48	L & T CR	M	20.00	Ft					
57	WEATHERING	L	4800.00	SqFt					
Sample Number:	41	Type:	R	Area:	4800.00 SqFt	PCI:	89		
Sample Comments:									
48	L & T CR	L	79.00	Ft					
57	WEATHERING	L	4800.00	SqFt					

Network:	32S	Name:	Stevensville Airport						
Branch:	TW	Name:	Taxiway	Use:	TAXIWAY	Area:	398,756 SqFt		
Section:	01	of 8	From:	Runway	To:	Apron, Turnarounds	Last Const.:	1/1/2021	
Surface:	AC	Family:	_MDT2024 - TW AC	Zone:	STEV	Category:	D	Rank:	P
Area:	7,709 SqFt	Length:	835 Ft	Width:	35 Ft				
Slabs:	Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft			
Shoulder:	Street Type:	STA	Grade:	0	Lanes:	0			
Section Comments:									
Work Date:	9/30/1991	Work Type:	New Construction - Initial		Code:	NU-IN	Is Major M&R:	True	
Work Date:	1/1/2021	Work Type:	Complete Reconstruction - AC		Code:	CR-AC	Is Major M&R:	True	
Last Insp. Date:	10/5/2024	Total Samples:	2	Surveyed:	1				
Conditions:	PCI:	94							
Inspection Comments:									
Sample Number:	01	Type:	R	Area:	5234.00 SqFt	PCI:	94		
Sample Comments:									
57	WEATHERING	L	5234.00	SqFt					

Network:	32S	Name:	Stevensville Airport					
Branch:	TW	Name:	Taxiway	Use:	TAXIWAY	Area:	398,756 SqFt	
Section:	02	of 8	From:	TW13	To:	TW02	Last Const.:	11/11/2017
Surface:	AC	Family:	_MDT2024 - TW AC	Zone:		Category:	Rank:	P
Area:	5,746 SqFt	Length:	97 Ft	Width:	46 Ft			
Slabs:		Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft	
Shoulder:		Street Type:		Grade:	0	Lanes:	0	
Section Comments:								
Work Date:	11/1/2017	Work Type:	Complete Reconstruction - AC	Code:	CR-AC	Is Major M&R:	True	
Work Date:	11/11/2017	Work Type:	New Construction - AC	Code:	NC-AC	Is Major M&R:	True	
Last Insp. Date:	10/5/2024	TotalSamples:	1	Surveyed:	1			
Conditions:	PCI: 89							
Inspection Comments:								
Sample Number:	01	Type:	R	Area:	4850.00 SqFt	PCI:	89	
Sample Comments:								
48	L & T CR	L	56.00	Ft				
57	WEATHERING	L	4850.00	SqFt				

Network: 32S **Name:** Stevensville Airport

Branch: TW **Name:** Taxiway **Use:** TAXIWAY **Area:** 398,756 SqFt

Section: 03 of 8 **From:** T-1 **To:** A-1 **Last Const.:** 6/1/1994

Surface: AC **Family:** _MDT2024 - TW AC **Zone:** STEV **Category:** D **Rank:** P

Area: 161,448 SqFt **Length:** 2,080 Ft **Width:** 35 Ft

Slabs: **Slab Length:** Ft **Slab Width:** Ft **Joint Length:** Ft

Shoulder: **Street Type:** ACM **Grade:** 0 **Lanes:** 0

Section Comments:

Work Date: 6/1/1994 **Work Type:** New Construction - Initial **Code:** NU-IN **Is Major M&R:** True

Last Insp. Date: 10/5/2024 **TotalSamples:** 26 **Surveyed:** 3

Conditions: PCI: 51

Inspection Comments:

Sample Number: 20 **Type:** R **Area:** 5250.00 SqFt **PCI:** 42

Sample Comments:

41	ALLIGATOR CR	L	190.00	SqFt
48	L & T CR	L	434.00	Ft
48	L & T CR	M	153.00	Ft
52	RAVELING	L	262.00	SqFt
57	WEATHERING	L	4463.00	SqFt
57	WEATHERING	M	525.00	SqFt

Sample Number: 23 **Type:** R **Area:** 5250.00 SqFt **PCI:** 60

Sample Comments:

45	DEPRESSION	L	35.00	SqFt
48	L & T CR	L	55.00	Ft
48	L & T CR	M	120.00	Ft
52	RAVELING	L	262.00	SqFt
57	WEATHERING	L	4463.00	SqFt
57	WEATHERING	M	525.00	SqFt

Sample Number: 25 **Type:** R **Area:** 6450.00 SqFt **PCI:** 52

Sample Comments:

41	ALLIGATOR CR	L	40.00	SqFt
48	L & T CR	L	105.00	Ft
48	L & T CR	M	430.00	Ft
57	WEATHERING	L	5482.00	SqFt
57	WEATHERING	M	968.00	SqFt

Network:	32S	Name:	Stevensville Airport				
Branch:	TW	Name:	Taxiway	Use:	TAXIWAY	Area:	398,756 SqFt
Section:	04	of 8	From:	NORTHWEST TAXIWAY	To:	OFF A-2	Last Const.: 8/1/2003
Surface:	AC	Family:	_MDT2024 - TW AC	Zone:	STEV	Category:	D
Area:	12,600 SqFt	Length:	360 Ft	Width:	35 Ft	Rank:	P
Slabs:	Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft	
Shoulder:	Street Type:	ACM	Grade:	0	Lanes:	0	
Section Comments:							
Work Date:	8/1/2003	Work Type:	New Construction - Initial	Code:	NU-IN	Is Major M&R:	True
Last Insp. Date:	10/5/2024	TotalSamples:	3	Surveyed:	3		
Conditions:	PCI: 76						
Inspection Comments:							
Sample Number:	01	Type:	R	Area:	4200.00 SqFt	PCI:	79
Sample Comments:							
45	DEPRESSION	L	8.00	SqFt			
48	L & T CR	L	105.00	Ft			
57	WEATHERING	L	3150.00	SqFt			
57	WEATHERING	M	1050.00	SqFt			
Sample Number:	02	Type:	R	Area:	4200.00 SqFt	PCI:	75
Sample Comments:							
45	DEPRESSION	L	44.00	SqFt			
48	L & T CR	L	47.00	Ft			
57	WEATHERING	L	3150.00	SqFt			
57	WEATHERING	M	1050.00	SqFt			
Sample Number:	03	Type:	R	Area:	4200.00 SqFt	PCI:	75
Sample Comments:							
48	L & T CR	L	90.00	Ft			
48	L & T CR	M	35.00	Ft			
57	WEATHERING	L	3360.00	SqFt			
57	WEATHERING	M	840.00	SqFt			

Network:	32S	Name:	Stevensville Airport				
Branch:	TW	Name:	Taxiway	Use:	TAXIWAY	Area:	398,756 SqFt
Section:	05	of 8	From:	Apron	To:	Hangars	Last Const.: 9/1/2013
Surface:	AC	Family:	_MDT2024 - TW AC	Zone:		Category:	Rank: P
Area:	71,505 SqFt	Length:	2,043 Ft	Width:	35 Ft		
Slabs:		Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft
Shoulder:		Street Type:	ACM	Grade:	0	Lanes:	0
Section Comments:							
Work Date:	9/1/2013	Work Type:	New Construction - Initial	Code:	NU-IN	Is Major M&R:	True
Last Insp. Date:	10/5/2024	TotalSamples:	13	Surveyed:	4		
Conditions:	PCI: 78						
Inspection Comments:							
Sample Number:	01	Type:	R	Area:	4200.00 SqFt	PCI:	80
Sample Comments:							
48	L & T CR	L	9.00 Ft				
48	L & T CR	M	33.00 Ft				
57	WEATHERING	L	3990.00 SqFt				
57	WEATHERING	M	210.00 SqFt				
Sample Number:	05	Type:	R	Area:	4575.00 SqFt	PCI:	77
Sample Comments:							
48	L & T CR	L	68.00 Ft				
48	L & T CR	M	34.00 Ft				
57	WEATHERING	L	4346.00 SqFt				
57	WEATHERING	M	229.00 SqFt				
Sample Number:	09	Type:	R	Area:	4575.00 SqFt	PCI:	78
Sample Comments:							
48	L & T CR	L	53.00 Ft				
48	L & T CR	M	25.00 Ft				
57	WEATHERING	L	4346.00 SqFt				
57	WEATHERING	M	229.00 SqFt				
Sample Number:	11	Type:	R	Area:	3875.00 SqFt	PCI:	78
Sample Comments:							
48	L & T CR	L	22.00 Ft				
48	L & T CR	M	33.00 Ft				
57	WEATHERING	L	3681.00 SqFt				
57	WEATHERING	M	194.00 SqFt				

Network:	32S	Name:	Stevensville Airport					
Branch:	TW	Name:	Taxiway	Use:	TAXIWAY	Area:	398,756 SqFt	
Section:	06	of 8	From:	R-11	To:	A-2	Last Const.:	11/1/2017
Surface:	AC	Family:	_MDT2024 - TW AC	Zone:		Category:	Rank:	P
Area:	50,188 SqFt	Length:	1,277 Ft	Width:	25 Ft			
Slabs:		Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft	
Shoulder:		Street Type:		Grade:	0	Lanes:	0	
Section Comments:								
Work Date:	11/1/2017	Work Type:	New Construction - AC	Code:	NC-AC	Is Major M&R:	True	
Last Insp. Date:	10/5/2024	TotalSamples:	9	Surveyed:	4			
Conditions:	PCI: 89							
Inspection Comments:								
Sample Number:	01	Type:	R	Area:	4970.00 SqFt	PCI:	86	
Sample Comments:								
48	L & T CR	L	16.00	Ft				
48	L & T CR	M	16.00	Ft				
57	WEATHERING	L	4970.00	SqFt				
Sample Number:	03	Type:	R	Area:	4970.00 SqFt	PCI:	89	
Sample Comments:								
48	L & T CR	L	53.00	Ft				
57	WEATHERING	L	4970.00	SqFt				
Sample Number:	07	Type:	R	Area:	4970.00 SqFt	PCI:	92	
Sample Comments:								
48	L & T CR	L	4.00	Ft				
57	WEATHERING	L	4970.00	SqFt				
Sample Number:	09	Type:	R	Area:	4970.00 SqFt	PCI:	92	
Sample Comments:								
48	L & T CR	L	6.00	Ft				
57	WEATHERING	L	4970.00	SqFt				

Network:	32S	Name:	Stevensville Airport					
Branch:	TW	Name:	Taxiway	Use:	TAXIWAY	Area:	398,756 SqFt	
Section:	12	of 8	From:	RW12	To:	TW13	Last Const.:	1/1/2021
Surface:	AC	Family:	_MDT2024 - TW AC	Zone:		Category:	Rank:	P
Area:	20,783 SqFt	Length:	185 Ft	Width:	56 Ft			
Slabs:		Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft	
Shoulder:		Street Type:		Grade:	0	Lanes:	0	
Section Comments:								
Work Date:	1/1/2021	Work Type:	New Construction - AC		Code:	NC-AC	Is Major M&R:	True
Last Insp. Date:	10/5/2024	TotalSamples:	5	Surveyed:	3			
Conditions:	PCI: 92							
Inspection Comments:								
Sample Number:	02	Type:	R	Area:	4140.00 SqFt	PCI:	94	
Sample Comments:								
57	WEATHERING		L	4140.00	SqFt			
Sample Number:	03	Type:	R	Area:	5468.00 SqFt	PCI:	94	
Sample Comments:								
57	WEATHERING		L	5468.00	SqFt			
Sample Number:	05	Type:	R	Area:	4232.00 SqFt	PCI:	88	
Sample Comments:								
48	L & T CR		L	85.00	Ft			
57	WEATHERING		L	4232.00	SqFt			

Network:	32S	Name:	Stevensville Airport					
Branch:	TW	Name:	Taxiway	Use:	TAXIWAY	Area:	398,756 SqFt	
Section:	13	of 8	From:	AP01	To:	TW01	Last Const.:	1/1/2021
Surface:	AC	Family:	_MDT2024 - TW AC	Zone:		Category:	Rank:	P
Area:	68,777 SqFt	Length:	2,000 Ft	Width:	35 Ft			
Slabs:		Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft	
Shoulder:		Street Type:		Grade:	0	Lanes:	0	
Section Comments:								
Work Date:	6/1/1994	Work Type:	New Construction - Initial		Code:	NU-IN	Is Major M&R:	True
Work Date:	1/1/2021	Work Type:	New Construction - AC		Code:	NC-AC	Is Major M&R:	True
Last Insp. Date:	10/5/2024	Total Samples:	15	Surveyed:	2			
Conditions:	PCI:	92						
Inspection Comments:								
Sample Number:	05	Type:	R	Area:	4935.00 SqFt	PCI:	91	
Sample Comments:								
48	L & T CR	L	13.00	Ft				
57	WEATHERING	L	4935.00	SqFt				
Sample Number:	11	Type:	R	Area:	4935.00 SqFt	PCI:	94	
Sample Comments:								
57	WEATHERING	L	4935.00	SqFt				